

Project Profile



Hybrid solar system for an outdoor BTS site with 1500W average power consumption

Description:

Likusasa designed and built a trial hybrid solar powered outdoor BTS site, with an average power consumption of 1500W, for Econet Zimbabwe.

Scope of Work:

The power system consisted of 2 arrays of polycrystalline PV modules with 6000Wp, 1500Ah REX deep cycling batteries, and a 20 kVA generator. The load consisted of a BTS unit with 1300W average consumption, a mini-link with 200W average consumption, and a cooling load of 90W peak. The site peak load was estimated at 2200W. The design configuration predicted a 60% renewable energy production component with a generator run-time of less than 1000 hours per annum.

A thermally insulated battery cabinet, which was shaded by the panels, was provided with free ambient cooling as standard. The rectifiers and solar charge controllers were cooled by a low power (90W peak) DC heat exchanger.



Likusasa

| Project Facts and Figures: | |
|------------------------------|--|
| Value | US \$60k |
| Location | 19.81° S, 32.73° E |
| Client | Econet Zimbabwe |
| Lead contractor | Likusasa Engineering and Contracting (Pty) Ltd |
| Start and duration | 2011 / 2 months |
| Solar insolation level | 5.74 kWh / m ² / day |
| PV array size | 6000Wp (30 x 200Wp) |
| PV array elevation | 24° |
| Site size | 18m x 13m |
| Solar energy produced | 10 576 kWh per annum |
| Excess solar energy produced | 14% |
| Site autonomy | 33 hours |
| Battery life | 7 years |
| Generator size | 20 kVA |
| Generator run time | 884 hours per annum |
| Generator life | > 10 years |